IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Exceeded Maximum Contaminant Level (MCL) for Haloacetic Acids

MONUMENTAL PSD, WV3302517

Our water system recently violated a drinking water standard. Although this is not an emergency, you, as our customers have the right to know what happened, what you should do, and what we are doing to correct the situation.

We routinely monitor for the presence of drinking water contaminants. Test results for 7/1/2026 and 9/30/2026 show that our system exceeds the standard or maximum contaminant level (MCL) for Haloacetic Acids.

The average level of Haloacetic Acids over the last four quarters was 61.0µg/L at BARRACKVILLE PUMP STATION NORTH PIKE ST. location. The standard for Haloacetic Acids is 60.0µg/L.

What should I do?

You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, it is recommended that you consult with your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing Haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

What happened? What is being done? (Describe corrective action)

Monumental PSD purchases water from the City of Fairmont. The contaminant levels are straight from the City of Fairmont, therefore there is nothing Monumental PSD can do to change the test results.

The City of Fairmont flushes their lines and Monumental PSD flushes their lines immediately afterwards Monumental PSD works with the City of Fairmont to keep their levels low, but due to the high heat of th season the levels were high.

For more information, please contact Monumental PSD (Contact name) at 304-363-1700 (Phone number)

Or 862 Husky Highway, Suite 1, Fairmont, WV 26554 (Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **MONUMENTAL PSD** 10/13/2026

State Water System ID #: WV3302517 Date Distributed: 10/16/2026