

**ENVIROTECH LABORATORIES, INC.****MA CERT. NO.: M-MA 063****8 Jan Sebastian Drive Unit 12****Sandwich, MA 02563****(508)888-6460 1-800-339-6460****FAX (508)888-6446****Client Name :** *Plymouth Estates***Location :****Address :** c/o Chris Shellin

Long Pond Beach

Plymouth, MA

Plymouth

02360

**Lab Number :** DW-263396**Collected By :** RPB**Date Received :** 08/03/26**Sample Type :** Pond water**Well Specs :**

| <i>Location Source</i><br><b>A</b> | <i>Date Collected</i><br><b>08/03/26</b> | <i>Time Collected</i><br><b>7:00</b> | <i>Comments</i>        |               |                      |                    |
|------------------------------------|------------------------------------------|--------------------------------------|------------------------|---------------|----------------------|--------------------|
| <i>Analysis Requested</i>          | <i>Units</i>                             | <i>Recommended Limits</i>            | <i>Analysis Result</i> | <i>Method</i> | <i>Date Analyzed</i> | <i>Analyzed By</i> |
| E coli-Pond                        | CFU/100 mL                               | 235                                  | 110                    | EPA 1603      | 08/03/2026           | BM@1600            |

**Comments:**

All samples were analyzed within the established guidelines of US EPA approved methods with all requirements met, unless otherwise noted at the end of a given sample's analytical results.

We certify that the following results are true and accurate to the best of our knowledge.

  
**Ronald J. Saari**  
**Laboratory Director****Date** 8/5/2026

AUG 05 2026